

Minter, Jill

From: Minter, Jill
Sent: Thursday, May 26, 2016 3:48 PM
To: Brown, Tim; ouisha.dean@solvay.com
Cc: Kahn, Lisa; Crosby, Jake; Pardue-Welch, Kimberly; Mifflin, Tiffany; Brian Mark (brian.mark@wyo.gov); Erica Larsen; Gary Hickman (ghickman@laramiecounty.com); Hannes Stueckler (hannes.stueckler@wyo.gov); James Brough (james.brough@wyo.gov); Jon Cecil; Karen Farley (karen.farley@wyo.gov); Kevin Frank (kevin.frank@wyo.gov); Kim Parker (kim.parker@wyo.gov); Mark Baron (mark.baron@wyo.gov); Mark Pepper; Mike Dart (mike.dart@wyo.gov); Paul Ng (ngp@sweet.wy.us); Rachael Heald (rheald@cnchd.org); Rich Cripe (rich.cripe@wyo.gov); Seth Tourney (seth.tourney@wyo.gov); Steven Kipp (steven.kipp@wyo.gov); Terri Gregory; Tracy Murphy (tracy.murphy@wyo.gov); William Tillman
Subject: Solvay Emergency Administrative Order (Sweetwater County) - BOIL ORDER DISCONTINUE and Notification to Discontinue Daily Total Coliform Monitoring

Since the daily total coliform and E. coli sampling from the Solvay Chemicals Public Water System (System) (PWS ID# 5600914) has been analyzed as safe for samples taken May 23, 24, and 25, 2016, the System may discontinue the boil order. Solvay Chemicals may also discontinue daily sampling and must now collect weekly samples (one sample per week starting next week) until notified in writing by the EPA that the System can return to monthly monitoring.

Thank you for your cooperation.

Jill Minter
Drinking Water Enforcement
USEPA Region 8 (8ENF-W)
1595 Wynkoop Street
Denver, CO 80202-8917
minter.jill@epa.gov
phone - 303-312-6084
fax - 303-312-7518